

2014 Collection System Repairs & Maintenance

City of Hazleton – System Repairs

- Poplar Street/Berner Avenue: Repaired sinkhole between sanitary and storm manholes and sealed abandoned pipe stub which had been allowing infiltration into system.
- 15th Street/Lincoln Street: Repaired defective manhole by rebuilding risers and replacing frame & cover
- Conahan Drive: Repaired defective manhole which had been allowing infiltration by rebuilding top riser.
- East Broad Street: Repaired defective manhole which had been allowing infiltration by rebuilding top riser.
- Christopher Drive: Repaired defective manhole by rebuilding risers and raised to grade
- Hayes Street & 13th Street: Located buried manholes and raised to grade. Replaced defective frames and covers.
- Wyoming Street & Maple Street: Repaired sinkhole at manhole. Repaired defective pipe connections into manhole which had been allowing infiltration.
- 15th Street/James Street/Peace Street: Repaired 3 defective manholes by rebuilding top risers and replacing frames & covers.
- Diamond Avenue & Laurel Street: Repaired sinkhole near stone arch. Repaired gap in stone which had been allowing infiltration and replaced loose backfill material.
- Carleton Avenue & East Street: Replaced approx. 120 linear feet of defective 6” main with new PVC and replaced 2 defective lateral connections which had been allowing infiltration.
- Raised to grade and replaced 65 defective sanitary manhole covers.

City of Hazleton – System Maintenance & Inspection Program

- Flushed and cleaned approximately 17,500 linear feet of mains.
- Flushed and cleaned 86 manholes.
- Closed circuit television (CCTV) inspection of approximately 11,000 linear feet of mains.

2014 Collection System Repairs & Maintenance

West Hazleton Borough – System Repairs

- 4th Street & Oak Street: Repaired defective manhole by rebuilding top riser and replacing frame & cover
- 5th Street & Clay Avenue: Repaired defective manhole by rebuilding top riser and replacing frame & cover
- Madison Avenue & Putnam Street: Repaired defective manhole by rebuilding top riser and replacing frame & cover
- Allen Street & Jefferson Avenue: Repaired sinkhole at stone arch. Repaired pipe connection to arch which had been allowing infiltration and stabilized area with flowable concrete fill.
- Jaycee Drive: Replaced 2 defective storm inlets.
- Deer Run Road: Repaired 3 defective storm inlets, replaced frames and grates.
- Raised 9 manholes to grade and replaced defective frames & covers.

West Hazleton Borough – System Maintenance & Inspection Program

- Flushed and cleaned approximately 10,000 linear feet of mains.
- Flushed and cleaned 37 manholes.
- Flushed and cleaned 26 storm inlets connected to combination mains.
- Closed circuit television (CCTV) inspection of approximately 6,000 linear feet of mains.