

RESOLUTION 001 of 2026

**RESOLUTION OF THE
GREATER HAZLETON JOINT SEWER AUTHORITY
LUZERNE COUNTY, PENNSYLVANIA
REVISING LOCAL LIMITS FOR THE DISCHARGE
OF POLLUTANTS FROM INDUSTRIAL USERS
AND REPEALING THOSE LOCAL LIMITS
ADOPTED BY PRIOR RESOLUTION**

WHEREAS, the Greater Hazleton Joint Sewer Authority (Authority) has developed and implemented a program for the control of industrial waste discharges within the service area by means of Authority Resolution Number 003 of 2015, as amended, called the Industrial Pretreatment Program Resolution; and

WHEREAS, the Industrial Pretreatment Program Resolution provides that the Authority may establish and amend from time to time specific discharge limits for industrial users, which limits are called Local Limits; and

WHEREAS, the Authority adopted Local Limits by resolution on June 16, 1993; and

WHEREAS, the Authority revised said Local Limits, by resolution dated November 20, 1995; August 23, 2004; February 16, 2011; and August 17, 2015; and

WHEREAS, the Authority wishes to amend the current Local Limits, as provided by the Industrial Pretreatment Program Resolution;

NOW, THEREFORE, the Greater Hazleton Joint Sewer Authority resolves as follows:

Article 1. The attached Schedule 1 of 2026, entitled Local Limits for Industrial Users, shall be and is hereby established as Local Limits authorized to be established by the Industrial Pretreatment Program Resolution, Article III Section 3.07 (Local Limits), and is attached hereto and hereby incorporated into and made a part of this Resolution. The discharge of industrial users shall be controlled so as to not exceed the Local Limits herein adopted, as provided by the Industrial Pretreatment Program Resolution (Resolution 003 of 2015).

Article 2. The maximum daily concentration limits and maximum allowable industrial loading limits adopted herein on Schedule 1 of 2026 may be applied to individual industrial users by means of limitations on concentration, as determined to be appropriate by the Pretreatment Coordinator.


Article 3. The attached Schedule 2 of 2026, entitled Site-Specific Criteria for Determination of Middle Tier Categorical Industrial Users, shall be and is hereby established as the criteria authorized to be established by the Industrial Pretreatment Program Resolution Article II definition of a Middle Tier Categorical Industrial User, and is attached hereto and hereby incorporated into and made a part of this Resolution.

Article 4 All previous Local Limits adopted by this Authority are hereby repealed in their entirety.

DULY ADOPTED, by the Board of Directors of the Greater Hazleton Joint Sewer Authority, in lawful session duly assembled, this 18th day of March 2026.


John Sullivan, Authority Chairman

ATTEST:


William Gallagher, Authority Secretary



CERTIFICATE

We, the undersigned, Chairman and Secretary, respectively, of GREATER HAZLETON JOINT SEWER AUTHORITY (the "Authority") hereby certify that the foregoing Resolution 001 of 2026 is a full, true and correct copy of a Resolution duly adopted by majority vote of the Board of Directors at a meeting of said Board duly convened and held according to law on March 18, 2026, that said Resolution was adopted by a roll call vote; that said Resolution and the vote thereon have been recorded in the minutes of said meeting; and that said Resolution remains in full force and effect, without alteration, amendment, modification or repeal, as of the date of this Certificate.

IN WITNESS WHEREOF, we hereunto affix our hands and the Secretary affixes the corporate seal of GREATER HAZLETON JOINT SEWER AUTHORITY, this 18th day of March, 2026.

GREATER HAZLETON JOINT SEWER AUTHORITY

BY:


John Sullivan, Authority Chairman

ATTEST:



William Gallagher, Authority Secretary



Greater Hazleton Joint Sewer Authority

Schedule 1 of 2026
Local Limits for Industrial Users

| Pollutants of Concern | Local Limits | |
|--------------------------------|--|------------------------------------|
| | Maximum Allowable Industrial Load Limits | Maximum Daily Concentration Limits |
| | (lbs/day) | (mg/L) |
| <i>Conventional Pollutants</i> | | |
| Biochemical Oxygen Demand | 17,000 | --- |
| Total Suspended Solids | --- | 2,000 |
| <i>Inorganics</i> | | |
| Arsenic, Total | --- | 1.30 |
| Cadmium, Total | --- | 0.045 |
| Chromium, Total | --- | 5.30 |
| Copper, Total | --- | 1.80 |
| Lead, Total | --- | 0.60 |
| Mercury, Total | --- | 0.0048 |
| Nickel, Total | --- | 4.1 |
| Selenium, Total | --- | 0.69 |
| Silver, Total | --- | 1.30 |
| Zinc, Total | --- | 2.50 |
| Cyanide, Total | --- | 0.52 |
| <i>Semi-Volatile Organics</i> | | |
| Bis (2-ethylhexyl) phthalate | --- | 0.04 |

Greater Hazleton Joint Sewer Authority

Schedule 2 of 2026
 Site-Specific Criteria for Determination of
 Middle Tier Categorical Industrial Users

To be permitted as a Middle Tier CIU, total categorical wastewater flows and loads cannot exceed the criteria presented in the table below.

| Definition Part & Criteria | |
|---------------------------------------|--|
| 1a | 0.01% of WWTP's Annual Average Daily Flow (gpd) |
| | 890 |
| 1b | 0.01% of WWTP's Annual Average Organic Capacity (lb./day) |
| | 1.87 |
| 1c | 0.01% of WWTP's Maximum Allowable Headworks Load (lbs/day) |
| | See Below |
| <i>Inorganics</i> | |
| | Arsenic, Total |
| | 0.0002 |
| | Cadmium, Total |
| | 0.00001 |
| | Chromium, Total |
| | 0.0023 |
| | Copper, Total |
| | 0.0004 |
| | Lead, Total |
| | 0.0001 |
| | Mercury, Total |
| | 0.000001 |
| | Nickel, Total |
| | 0.0009 |
| | Selenium, Total |
| | 0.0001 |
| | Silver, Total |
| | 0.0002 |
| | Zinc, Total |
| | 0.0023 |
| | Cyanide, Total |
| | 0.0001 |
| <i>Semi-Volatile Organics</i> | |
| | Bis (2-ethylhexyl) phthalate |
| | 0.00004 |