

2016 Collection System Repairs & Maintenance (thru June 30)

City of Hazleton – System Repairs and Improvements

- Bunton Bock Area Sewer Separation & Improvement Projects:
 - Constructed new separate sanitary sewer mains on Mill Street, Hazle Street, Mine Street, Elm Street, Walnut Street and Beech Street. Approximately 6,700 linear feet of new sanitary sewer pipe and 49 new manholes installed through June 30. Connected approximately 208 sanitary laterals to new sanitary mains. Overall project is at approximately 85% complete through June 30, 2016.
 - Performed dye testing and investigative work related to eliminating storm inlets and roof drains from sanitary system. Approximately 50 roof drain leaders removed from sanitary sewer mains.
- Oliver Court Right-of-Way main repair: Replaced 5 linear feet of defective 12” TCP pipe which had been allowing infiltration with new 12” PVC pipe.
- Birch Knoll Right-of-Way main repair: Replaced 15 linear feet of defective 12” TCP pipe which had been allowing infiltration with new 12” PVC pipe.
- Wyoming & Maple sinkhole repair: Repaired manhole riser and replaced defective frame & cover which had been allowing infiltration. Removed loose fill material and replaced with flowable concrete fill.
- Hemlock Street main repair: Replaced 40 linear feet of damaged 8” TCP pipe with new 8” PVC pipe.
- Repaired, raised to grade and replaced defective frames and covers for 18 manholes.

City of Hazleton – System Maintenance & Inspection Program

- Flushed and cleaned approximately 16,000 linear feet of mains.
- Flushed and cleaned 56 manholes.
- Closed circuit television (CCTV) inspection of approximately 1,200 linear feet of mains.

West Hazleton Borough – System Repairs and Improvements

- Modified 8 storm inlets connected to combination mains to reduce amount of large debris inflow into system.
- Repaired defective storm inlet connected to combination main.
- Repaired, raised to grade and replaced defective frames and covers for 2 manholes.

West Hazleton Borough – System Maintenance & Inspection Program

- Flushed and cleaned approximately 1,000 linear feet of mains.
- Flushed and cleaned 4 manholes.
- Flushed and cleaned 16 storm inlets connected to combination mains.
- Closed circuit television (CCTV) inspection of approximately 500 linear feet of mains.