

2025 Collection System Repairs & Maintenance

City of Hazleton – System Repairs and Improvements

- Completion of Areas 2 & 3 Force Main Replacement & CSO Sewer Separation Project:
 - Replaced approximately 3,000 linear feet of 12” ductile iron force main from the Locust Street Pump Station to the Maple Street valve chamber.
 - Installed approx. 10,500 lf of new sanitary sewer mains, 60 new sanitary manholes, 750 lf of new storm mains, and 5 new storm inlets.
 - Completed repairs to 13 sanitary sewer cross-connections which had been connected to storm mains.
 - Completed full width street paving of affected areas.
 - Disconnected 178 roof drain leaders from sanitary mains.
- Area 10 Partial Sewer Separation Project:
 - Continued field survey work, engineering and mapping for design of sanitary sewer/stormwater separation project.
 - Continued flow monitoring at 3 locations for pre-construction flow study.
 - Disconnected 26 roof drain leaders from sanitary mains
- Samuels Avenue main repairs: Replaced approx. 10 lf of 8” VCP pipe with new PVC pipe.
- Hayes Street main repairs: Replaced approx. 10 lf of 8” VCP pipe with new PVC pipe. Rebuilt manhole riser and raised to grade.
- Repaired, raised to grade and replaced defective frames and covers for 40 manholes.

City of Hazleton – System Maintenance & Inspection Program

- Flushed and cleaned approximately 14,000 linear feet of mains.
- Flushed and cleaned 69 manholes.
- Completed root control treatment program with approximately 4,500 linear feet of mains treated on various streets.
- Closed circuit television (CCTV) inspection of approximately 17,400 linear feet of mains.
- Continued flow monitoring study with flowmeters installed at 14 locations.

2025 Collection System Repairs & Maintenance

West Hazleton Borough – System Repairs and Improvements

- Various streets manhole repairs: Repaired manhole risers, raised to grade and replaced castings for 6 manholes on West 22nd Street, Dessen Drive, and Kiwanis Boulevard.
- Continued root control treatment program with approximately 6,000 linear feet of mains treated on Susquehanna Boulevard, Jaycee Drive, Kiwanis Boulevard, Ridge Avenue, and North Street.

West Hazleton Borough – System Maintenance & Inspection Program

- Flushed and cleaned approximately 3,000 linear feet of mains.
- Flushed and cleaned 11 manholes.
- Closed circuit television (CCTV) inspection of approximately 5,000 linear feet of mains.
- Continued flow monitoring study with flowmeters installed at 8 locations.